

OFFICE OF THE MEMBER (WATER)
DELHI JAL BOARD; GOVT OF NCT OF DELHI
VARUNALYA PH II NEW DELHI


No. DJB/Member(W))/2004/4490

DATED 27/8/04

INSTRUCTIONAL ORDER

In partial modification to the Instructional Order dt. 9.6.2004, the following criteria is hereby ordered for procurement of new motors for various water supply installations: -

- | | |
|---|---|
| 1. For motors including & upto 100 HP
LT Supply | Squirrel cage motors with star delta
Starters. |
| 2. For motors including & upto 200 KW
LT Supply
(For duties other than UGR/BPS) | Squirrel cage motors with soft
Starters. |
| 3. For motors including & upto 325 KW
LT Supply
(For duties at UGR/BPS application) | Squirrel cage motors with soft
Starters. |
| 4. For motors above 200 KW
HT Supply
(For duties other than UGR/BPS) | Squirrel cage motors with soft
Starters. |
| 5. For motors above 325 KW
HT Supply
(For duties at UGR/BPS application) | Squirrel cage motors with soft
Starters. |



Asst Chief Engineers

Copy to :

CEO / Member (Dr.) for information please.
PM(WBPC)/ SE(WW) I/SE(E&M) W&S II/SE(E&M)WC
EE(E&M)WBPC/EE(C)WBPC.

MEMBER (W)

M/WS/1350/S
31/8/04

31/8/04

file

27/8/04