

DELHI JAL BOARD
OFFICE OF THE DIRECTOR (REVENUE)
VARUNALAYA PHASE-II, KAROL BAGH, NEW DELHI-110005.

NO. DJB/DOR/2015/ 560


Dated : 16-01-2015.

Subject: Notification regarding material for installation of all new House Service Connection in Delhi.

A Study Group comprising S.Es/E.Es of D.J.B. was formed for suggesting measures for reduction of Non-Revenue Water (NRW) by replacement of House Service Connections. Study Group suggested mandatory use of improved material for House Service Connections while installing new water connections. The recommendations of the Study Group have been accepted by the competent authority. Accordingly, House Service Connection pipe arrangement from ferrule to meters will be as under :-

1. Tapping with Saddle (DI or MDPE composite) – the bore size to be maintained as 8 mm or as sanctioned with additional control through adopter of same (bore) size fitted in the saddle.
2. MDPE pipe for underground portion, conforming to minimum PE80 grade ISO specifications (ISO 4427 and BS 6730-1986) for carrying potable water.
3. GI pipe of class 'B' conforming to relevant IS code for above ground portion up to water meter.

This requirement is also being included in the new water connection forms for the information of the applicants.



(H.V. TANDON)
DIRECTOR (REVENUE)


All Z.R.Os.


All Ex. Engineers (Maintenance) for ensuring above guidelines through concerned Z.Es/J.Es.

Copy to:

1. P.S. to Hon'ble L.G., Delhi for kind information.
2. P.S. to Secretary (U.D.) for kind information.
3. All Members of the Board for kind information.
4. Secretary to CEO (DJB).
5. Member (Admn.) / Member (Finance) / Member (WS) / Member (Dr.)/CVO for kind information.
6. All C.Es (Maintenance).
7. Director (F&A)/ Director (A&P)/ DOV/ Secretary (DJB).
8. All S.Es (Maintenance)/ Jt. Dir.(F&A)-I & II / All Dy. A&FOs / Dy.Dir.(Enforcement).
9. All Jt. Directors(Revenue)/All Dy. Directors(Revenue) – with the directions to ensure compliance and organizing meeting with Plumbers Association to contact them to follow the above guidelines.
10. Incharge, EDP Cell for information with request to display the same on DJB's website.
11. Consultant (PR) with 10 spare copies for wide publicity in News Papers along with CD.
12. Project Managar, TCS Ltd., Site Office, 6th Floor, Varunalaya Phase-II, Karol Bagh, New Delhi : for including these requirements in the new water connection forms..
13. License Plumbers Association for information and necessary compliance.
14. Guard File.


16.1.15
DIRECTOR (REVENUE)


27/1


19/1