

**Stop Corona**

(i) Wash Your Hands, (ii) Wear Mask, (iii) Maintain Social Distance


DELHI JAL BOARD: GOVT. OF NCT OF DELHI  
OFFICE OF THE EXECUTIVE ENGINEER(EAP)-I  
ROOM NO. 501, VARUNALAYA PHASE-I, KAROL BAGH,  
NEW DELHI-110005  
Email :- [eeeap1.djb@gmail.com](mailto:eeeap1.djb@gmail.com)

Name of Work : "Improvement of Water Supply System including Operation and Maintenance of Transmission & Distribution Pipes, Pumping Stations, Service Connections and Consumer Meters with DMA formation and NRW Reduction in Chandrawal WTP Command Area, Package - 3 (Central)".  
-JICA Assisted DWSIP in Chandrawal WTP Command Area (Loan ID-P 225)

**Corrigendum and Addendum No. 4**  
**NIT No. 02(2021-22)/EE(EAP)-I(Re-invited)**

This is in continuation to the earlier Corrigendum and Addendum No. 1,2 & 3. The Corrigendum and Addendum No. 4 is as under:

S.N.	Volume	Page	Clause	Corrigendum and Addendum								
1.	II	829	Part-2, Section VI, D, O&M Sub-Section 2, KPI for O&M, Table-1, Performance Target to be achieved for NRW (Water Loss)	<b>The Table – 1 stands deleted and revised table may be read as under:</b>  NRW during Post Construction O&M Period shall be as under:								
				No. of years after start of O&M Period (Post Construction)	3 years	4 years	5 years	6 years	7 years	8 years	9 years	10 years
				Non-Revenue Water (Water Loss)	35%	30%	25%	20%	15%	15%	15%	15%

  
(B S Rawat)  
EE (EAP)-I

13/2




No. DJB/EE (EAP)-I/2021/ 2307-2355

Dated: 13.07.2021

Copy to:-

1. P.S. to Vice Chairman, DJB
2. Secy. to CEO/Member (A)/Fin/Dr./WS
3. All CE's
4. Under Secretary(JICA), DEA, Ministry of Finance, North Block, New Delhi
5. Dir. (F&A)/ Addl.CEO/ DOV, DJB
6. JICA INDIA
7. SE(Project) Water-I,II,III, IV, V./ (Planning)W/ SE(E&M)WC
8. ALL EE(Project) Water
9. AO(Project) Water-III/ AAO(EAP)-I
10. All AEs(EAP)-I
11. PMSC
12. Contractors Welfare Association registered, 20 FF, LSC, BQ Block, DDA Mkt., Shalimar Bagh, Delhi-88.
13. EE(EDP): with softcopy to upload on DJB Website

EE (EAP)-I

  
13/7