



DELHI JAL BOARD: GOVT. OF N.C.T OF DELHI
OFFICE OF THE EXECUTIVE ENGINEER
40 MGD W.T.P. NANGLOI, NEW DELHI



"STOP CORONA; WEAR MASK, FOLLOW PHYSICAL DISTANCING, MAINTAIN HAND HYGIENE"

NO: DJB/EE(E&M)IWTP-N/ 2021/ 637

Dated: 31.07.2021

Expression of Interest

Delhi Jal Board, Dwarka Water Works intends to execute the work of Design, Build, Installation, Testing and Commissioning of 20 MGD water treatment plant/ Ozonization plant suitable for mixing with raw water / UGR water with OZONIZATION/ FILTRATION / AIRATION system for treatment of effluent of sewerage treatment plant having tertiary treatment (Physicochemical) parameters as:-

1. Colour- Clear, PH Value-7.7, Turbidity- 2.9 (NTU), Total Suspended Solid- 08 (mg/l), NH₃- 4.0 (mg/l), Soluble NH₃-N- 3.0 (mg/l), Particulate NH₃-N- 01(mg/l), PO₄³-P- 1.2(mg/l), Soluble PO₄³-P- 1.0(mg/l), Particulate PO₄³-P- 0.2(mg/l), Soluble BOD- 03(mg/l), Particulate BOD- 03(mg/l), COD- 53(mg/l), Soluble COD- 60(mg/l), Particulate COD- 04(mg/l), Hardness- 296(mg/l), TDS- 955(mg/l), Faecal Coliform- 21X10⁴ (MPN), to be made suitable for mixing with raw water/ UGR water with 3 years O&M at Dwarka Water treatment plant.
2. All the agencies / experts in this field are requested to submit their proposal with complete specification, technology to be adopted, clear Terms and Conditions, land/ area required etc. with tentative expenditure incurred in both the cases as applicable to Government/ Semi Government department within 10 days (i.e. up to 11.08.2021 at 3.00P.M.). Interested firms may contact to Sh. K.G.Mishra, Executive Engineer, Mob: 9650291163/ Sh. Yogesh Lohchab, AE(E&M), Mob: 9650777672 for clarification / information if any. E-Mail: eewtpnangloi@gmail.com



Sd/-
Ex. Engineer (E&M) WTP-N

Copy to:-

1. CE(WW) : For kind information
2. DTQC/SE(WW)II : -do-
3. EE(EDP) : For uploading on DJB website.
4. PRO(W) : With 10 spare copies to publish in leading newspapers.
5. AO(WW)II/AAO Nangloi
6. AE(E&M)II
7. Case file/Office copy

Prag I

EE(EDP) AB
AE(EDP) 02-08-21

31/7/2021
(K.G.Mishra)

Ex. Engineer (E&M) WTP-N